

Compliance Statement

No. 2019-155

Data communication cable, Category 7

Company

KRUGEL EXIM spol s r.o.
Rybničná 38/H
831 06 Bratislava
Slovakia

Product description

Screened cable (S/FTP) characterised up to 1000 MHz*
Horizontal floor wiring cable, 100 Ω
4 individually foil screened twisted pairs with overall braid screen
Flame retardant, halogen free

Product identification

KELine 10Giga 1000MHz, S/FTP 4x2xAWG23 Cat.7, LSOH
Part number: KE1000HS23

Generic cabling and cabling components standards - Category 7 cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2012 (Ed. 2.1)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-4-1:2013

Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2011 (Ed. 2.0)
- IEC 61034-1:2013 (Ed. 3.1) / IEC 61034-2:2013 (Ed. 3.1)

Technical report

T923889-02, DANAK-19/19990

EC Cabling product ID


6218

CS valid until

1 March 2020

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 22 February 2019


Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department